



ACB (INDIA) LIMITED

30 MW Chakabura Power Plant, P.O.- Jawali, Tehsil-Katghora,
Distt.Korba (C.G) 495 445, Tel : 07815-285511, 285512,
fax : 07815-285884, 285885, Email : poweraryan@yahoo.com.
Email : aryanpower30@gmail.com

TO WHOM SO EVER IT MAY CONCERN

Date-19/04/2013.

To
M/S. ANPAM ENGINEERING,
9/1, A-7, Kumaramangalam Indl. Estate,
Mathur - 622515. Pudukkottai District.
Tamil Nadu.


Kind Attn: Mr. A.P.Maheshwara

Dear Sir,

Sub: Performance Certificate for Start-up Vent Silencer - Reg.

Ref: PO No. : ACB/30MW/11-12/R-244 and your Vendor code - C-A0318.

This is to certify that the design, engineering, manufacturing, supply of **Start-up Vent Silencer** by **M/S.ANPAM ENGINEERING** has been received and working satisfactorily. The Silencer confirms to all technical details stipulated. The noise level after installation has **brought down to 85 dBA**, against a guaranteed Noise level of 90 dBA.


GENERAL MANAGER (30MW PP)
ACB (INDIA) LIMITED
CHAKABURA, KORBA