



NIRANI SUGARS LIMITED

Kulali Cross, Jamkhandi Road,
MUDHOL - 587 313. Dist : Bagalkot Karnataka state

TO WHOM SO EVER IT MAY CONCERN

21st May, 2013

To
M/S. ANPAM ENGINEERING,
9/1, A-7, Kumaramangalam Indl. Estate,
Mathur - 622515. Pudukkottai District.
Tamil Nadu.

Kind Attn: Mr. A.P.Maheshwara

Dear Sir,

Sub: Performance Certificate for Steam Vent Silencer - Reg.
Ref: PO No. : PUR/CO-GEN/2011-2012/784.

This is to certify that the design, engineering, manufacturing, supply of **Steam Vent Silencer of 15TPH** by **M/S.ANPAM ENGINEERING** has been received and working satisfactorily. The Silencer confirms to all technical details stipulated. The noise level after installation has **brought down to 85 dBA**, against a guaranteed Noise level of 90 dBA.

for **NIRANI SUGARS LIMITED,**


M.S.Hattikal

Chief General Manager (Tech)



NIRANI SUGARS LIMITED

Kulali Cross, Jamkhandi Road,
MUDHOL - 587 313. Dist : Bagalkot Karnataka state

TO WHOM SO EVER IT MAY CONCERN

21st May, 2013

To
M/S. ANPAM ENGINEERING,
9/1, A-7, Kumaramangalam Indl. Estate,
Mathur - 622515. Pudukkottai District.
Tamil Nadu.

Kind Attn: Mr. A.P.Maheshwara

Dear Sir,

Sub: Performance Certificate for Steam Vent Silencer - Reg.

Ref: PO No. : PUR/CO-GEN/2011-2012/784.

This is to certify that the design, engineering, manufacturing, supply of **Steam Vent Silencer of 20TPH** by **M/S.ANPAM ENGINEERING** has been received and working satisfactorily. The Silencer confirms to all technical details stipulated. The noise level after installation has **brought down to 85 dBA**, against a guaranteed Noise level of 90 dBA.

for **NIRANI SUGARS LIMITED,**


M.S.Hattikal

Chief General Manager (Tech)



NIRANI SUGARS LIMITED

Kulali Cross, Jamkhandi Road,
MUDHOL - 587 313. Dist : Bagalkot Karnataka state

TO WHOM SO EVER IT MAY CONCERN

21st May, 2013

To
M/S. ANPAM ENGINEERING,
9/1, A-7, Kumaramangalam Indl. Estate,
Mathur - 622515. Pudukkottai District.
Tamil Nadu.

Kind Attn: Mr. A.P.Maheshwara

Dear Sir,

Sub: Performance Certificate for Steam Vent Silencer – Reg.
Ref: PO No. : PUR/CO-GEN/2011-2012/784.

This is to certify that the design, engineering, manufacturing, supply of **Steam Vent Silencer of 30TPH** by **M/S.ANPAM ENGINEERING** has been received and working satisfactorily. The Silencer confirms to all technical details stipulated. The noise level after installation has **brought down to 85 dBA**, against a guaranteed Noise level of 90 dBA.

for **NIRANI SUGARS LIMITED,**


M.S.Hattikal

Chief General Manager (Tech)